



## Instruction

- 1 The LED controller type of PHC heat and cool unit is HC35G and circuit board type is FL003. change 2 to t2'; parameter of t2 is 10k, and parameter of t2' is 5k.
- 2 There is no filter 2 in PH single heat type.
- 3 There is no strip heater for the compressor in types under/included PH45.
- 4 There is no AC contactor in types under/included PH20 .